

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0324:100 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Security Door Controls, 3580 Willow Lane, Westlake Village CA 91361
*Contact: David Geringer (805) 494-8680 Fax (805) 494-8680

DESIGN: EMLock 1500 electric exit lock models 1511, 1512, 1521, 1522, 1561, 1562, 1565, 1566, 1571, 1572, 1575, 1576, 1581, 1582, 1585 and 1586. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as auxiliary locking device for fire-rated and non fire-rated doors to prevent un-wanted entry and unauthorized exit when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Formerly 4136-0324:100

*Rev. 05-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager